

NORTH TEXAS MUNICIPAL WATER DISTRICT - Wylie

Water Analysis

Jul-2021

Mineral Analysis	Raw	Treated	Standards			
			EPA Primary	EPA Secondary	TCEQ Primary	TCEQ Secondary
	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)
Residue on Evaporation	302	387		500		1000
Silica (SiO2)	5.67	4.83				
Iron (Fe)	0.625	0.592		0.3		0.3
Calcium (Ca)	46.7	52.1				
Magnesium (Mg)	6.70	6.26				
Sodium (Na)	35.2	56.1				
Potassium (K)	4.38	4.29				
Sulfate (SO4)	44.6	95.7		250		
Nitrite (NO2)	<0.0100	<0.0100	1		1	
Nitrate (NO3)	<0.0500	0.0980	10		10	
Chloride (Cl)	42.0	52.4		250		300
Fluoride (F)	0.230	0.221 *	4.0	2.0	4.0	2.0
Phosphates (PO4)	0.669	0.0230				

	(mg/L as CaCO3)	(mg/L as CaCO3)	(mg/L as CaCO3)	(mg/L as CaCO3)	(mg/L as CaCO3)	(mg/L as CaCO3)
Total Alkalinity	118 *	104 *				
Total Hardness	142	146				
Langelier Index		0.6750				

Trace Element Analysis

	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)
Arsenic (As)	0.00471	0.00105	0.01		0.01	
Barium (Ba)	0.0601	0.0544	2		2	
Cadmium (Cd)	<0.000500	<0.000500	0.005		0.005	
Chromium (Cr)	<0.00125	<0.00125	0.1		0.1	
Copper (Cu)	0.00711	0.00378	1.3	1	1.3	1.0
Iron (Fe)	0.625	0.592		0.3		0.3
Lead (Pb)	0.000284	<0.000250	0.015		0.015	
Manganese (Mn)	0.0696	0.0119		0.05		0.05
Mercury (Hg)	<0.0000500	<0.0000500	0.002		0.002	
Nickel (Ni)	0.00461	0.00668				
Selenium (Se)	0.00119	0.000743	0.05		0.05	
Silver (Ag)	<0.000250	<0.000250		0.10		0.1
Zinc (Zn)	0.00765	0.00860		5		5

Other Analysis

Chlorine Residual (mg/L)	--	3.67 *	4.0		4.0	
Total coliform (Present / Absent)	--	A *	A		A	
pH (Standard Units) @ 25°C	8.00 *	8.25 *		6.5 - 8.5		>7.0
Specific Conductance (Umhos)	472 *	594 *				
Turbidity (NTU)	12.8 *	0.0782 *	0.3		0.3	
Threshold Odor Number	8	1				3

Note 1: National Primary Drinking Water Regulations or Primary Standards are legally enforceable standards. National Secondary Drinking Water Regulations or Secondary Standards are non-enforceable guidelines regulating contaminants that may cause cosmetic or aesthetic effects In Drinking Water.

Note 2: TCEQ Primary Standards are the maximum contaminant level allowed for each constituent. TCEQ Primary Standards are legally enforceable standards.

Note 3: * Identifies Monthly Average Process analyses.