

NORTH TEXAS MUNICIPAL WATER DISTRICT - Wylie

Water Analysis

Apr-2022

Mineral Analysis	Raw	Treated	Standards			
			EPA Primary	EPA Secondary	TCEQ Primary	TCEQ Secondary
	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)
Residue on Evaporation	294	370		500		1000
Silica (SiO2)	4.99	4.44				
Iron (Fe)	0.486	<0.200		0.3		0.3
Calcium (Ca)	54.5	53.7				
Magnesium (Mg)	6.50	7.07				
Sodium (Na)	35.5	57.8				
Potassium (K)	5.92	5.79				
Sulfate (SO4)	104	111		250		
Nitrite (NO2)	<0.0200	<0.0200	1		1	
Nitrate (NO3)	0.368	0.449	10		10	
Chloride (Cl)	82.4	108		250		300
Fluoride (F)	0.289	0.288 *	4.0	2.0	4.0	2.0
Phosphates (PO4)	0.105	<0.0200				

	(mg/L as CaCO3)	(mg/L as CaCO3)	(mg/L as CaCO3)	(mg/L as CaCO3)	(mg/L as CaCO3)	(mg/L as CaCO3)
Total Alkalinity	138 *	116 *				
Total Hardness	166	170				
Langelier Index		0.5270				

Trace Element Analysis

	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)
Arsenic (As)	0.00135	<0.00050	0.01		0.01	
Barium (Ba)	0.0600	0.0512	2		2	
Cadmium (Cd)	<0.00100	<0.00100	0.005		0.005	
Chromium (Cr)	<0.00250	<0.00250	0.1		0.1	
Copper (Cu)	0.00724	0.00248	1.3	1	1.3	1.0
Iron (Fe)	0.486	<0.200		0.3		0.3
Lead (Pb)	0.000515	<0.000500	0.015		0.015	
Manganese (Mn)	0.0380	<0.0250		0.05		0.05
Mercury (Hg)	<0.000100	<0.000100	0.002		0.002	
Nickel (Ni)	0.00496	0.00695				
Selenium (Se)	<0.00100	<0.00100	0.05		0.05	
Silver (Ag)	<0.000500	<0.000500		0.10		0.1
Zinc (Zn)	0.00915	0.00709		5		5

Other Analysis

Chlorine Residual (mg/L)	--	3.70 *	4.0		4.0	
Total coliform (Present / Absent)	--	A *	A		A	
pH (Standard Units) @ 25°C	8.24 *	8.28 *		6.5 - 8.5		>7.0
Specific Conductance (Umhos)	478 *	608 *				
Turbidity (NTU)	21.5 *	0.0677 *	0.3		0.3	
Threshold Odor Number	<1.00	<1.00				3

Note 1: National Primary Drinking Water Regulations or Primary Standards are legally enforceable standards. National Secondary Drinking Water Regulations or Secondary Standards are non-enforceable guidelines regulating contaminants that may cause cosmetic or aesthetic effects In Drinking Water.

Note 2: TCEQ Primary Standards are the maximum contaminant level allowed for each constituent. TCEQ Primary Standards are legally enforceable standards.

Note 3: * Identifies Monthly Average Process analyses.