

Total Chlorine Residual			Units - mg/L					
Date	1/8/22	1/9/22	1/10/22	1/11/22	1/12/22	1/13/22	1/14/22	
Day	Sat	Sun	Mon	Tue	Wed	Thu	Fri	
F1 PS	2.86	3.25	2.95	3.32	3.44	3.08	3.07	
F2 PS	3.08	3.15	3.20	3.44	3.32	3.04	3.01	
Hill EST	2.69	2.71	2.85	3.06	3.11	3.08	2.86	
Eldo EST	O/S	O/S	O/S	O/S	O/S	O/S	O/S	
Park EST	1.33	1.22	1.28	1.55	1.62	1.70	1.54	
Timb EST	2.60	2.45	2.60	2.68	2.77	2.90	2.77	
Teel EST	2.62	2.41	2.62	2.99	2.83	2.93	2.73	
Leg EST	1.21	1.11	1.11	1.26	1.43	1.53	1.55	
Stone EST	1.79	1.60	1.86	1.91	2.03	2.21	1.98	
Hack - Dev	1.30	1.28	1.11	2.00	1.91	1.73	1.61	
			2.49	2.74	1.30	2.45		
			1.22	2.66	0.56	2.09		
			2.04	2.69	3.12	2.55		
			3.17	2.39	3.10	2.52		
			3.23	2.44	3.22	2.97		
			3.10		3.30			
			3.02		3.22			
			2.45		3.19			
			0.52		2.80			
			2.77		1.34			
		Range						
Previous Week	Average Low limit	MIN		Average		MAX	Average High Limit	
93 samples	0.5	0.52		2.38		3.44	4.00	
January								
186 samples	0.5	0.52		2.26		3.53	4.00	

OS - Eldorado EST is out of service for maintenance and repairs.

Bacteriological Sampling		N - Negative	P - Positive
Date	Site	Subdivision	Results
1/10/2022	31	QUAIL MEADOW	N
1/10/2022	32	STONBRIAR	N
1/10/2022	33	WILLOW POND	N
1/10/2022	34	PLANTATION	N
1/10/2022	35	RICHWOODS	N
1/10/2022	36	CYPRESS CREEK	N
1/10/2022	37	FRISCO HEIGHTS	N
1/10/2022	38	PANTHER CREEK	N
1/10/2022	39	PRESTON HIGHLANDS	N
1/10/2022	40	COBB HILL	N
1/11/2022	41	GRIFFIN PARK	N
1/11/2022	42	PEARSON VINEYARD	N
1/11/2022	43	STONE WATER CROSSING	N
1/11/2022	44	FRISCO LAKES	N
1/11/2022	45	QUAIL MEADOW	N
1/12/2022	46	KINGSWOOD	N
1/12/2022	47	STONEBRIAR	N
1/12/2022	48	PRESTON VINEYARDS	N
1/12/2022	49	PRESTON OAKS	N
1/12/2022	50	LIBERTY CROSSING	N
1/12/2022	51	TURNBRIDGE	N
1/12/2022	52	PLANTATION	N
1/12/2022	53	CUSTER CREEK FARMS	N
1/12/2022	54	WILLOW BAY	N
1/12/2022	55	MEADOW HILL ESTATES	N
1/13/2022	56	HEATHER RIDGE	N
1/13/2022	57	GREYHAWK	N
1/13/2022	58	WEST FALLS VILLAGE	N
1/13/2022	59	PARK PLACE	N
1/13/2022	60	WOODSTREAM	N
Month to Date			
Total Samples	60	City Wide	N
Total Samples	0	City Wide	P*
* All repeat samples tested negative; no further action required.			

Disinfection By-products					Units - ug/L	
Total Trihalomethane (TTHM)						
Site	Previous 4 Quarterly Samples				LRAA (80)	
1	26.2	20.8	26.8	43.4		29.3
2	25.4	21.0	28.2	44.4		29.8
3	25.6	23.5	24.5	43.3		29.2
4	26.4	23.9	26.9	39.1		29.1
5	25.8	25.5	28.6	36.8		29.2
6	25.6	23.8	25.5	42.3		29.3
7	26.3	25.5	25.5	44.9		30.6
8	25.9	21.8	27.2	41.7		29.2
	Q4 - 20	Q1 - 21	Q2 - 21	Q3 - 21		

Total Haloacetic Acids (HAA)						
Site	Previous 4 Quarterly Samples				LRAA (60)	
1	17.0	22.0	23.0	33.1		23.8
2	17.0	22.0	23.3	32.3		23.7
3	18.0	19.0	19.4	35.1		22.9
4	15.0	28.0	24.3	32.3		24.9
5	16.0	24.0	23.7	31.9		23.9
6	18.0	20.0	21.1	32.4		22.9
7	13.0	21.0	18.1	32.1		21.1
8	18.0	23.0	23.1	33.8		24.5
	Q4 - 20	Q1 - 21	Q2 - 21	Q3 - 21		