

Total Chlorine Residual			Units - mg/L				
Date	4/24/21	4/25/21	4/26/21	4/27/21	4/28/21	4/29/21	4/30/21
Day	Sat	Sun	Mon	Tue	Wed	Thu	Fri
F1 PS	3.18	3.19	3.27	3.29	2.94	3.09	2.92
F2 PS	2.99	3.12	3.12	3.22	2.99	2.82	2.93
Hill EST	3.13	3.19	3.19	3.16	3.11	2.98	2.93
Eldo EST	3.08	3.23	3.19	3.18	3.07	3.03	2.82
Park EST	3.02	3.00	3.16	2.87	2.93	2.92	2.82
Timb EST	2.97	3.04	3.07	3.17	3.10	3.11	2.89
Teel EST	2.97	3.03	3.07	3.09	3.24	2.98	2.94
Leg EST	2.94	3.03	2.86	2.98	2.93	2.95	2.74
Stone EST	2.91	2.83	2.99	3.00	2.94	3.00	2.94
Hack - Dev	2.95	3.22	2.96	2.90	3.03	2.98	2.92
			2.40	2.07	2.06	2.24	
			2.21	2.43	1.52	1.86	
			2.34	2.16	2.14	2.29	
			2.90	2.11	2.05	2.73	
			2.30	2.29	2.86	2.22	
			2.43		2.02		
			2.39		1.81		
			2.31		2.23		
			2.12		2.58		
			1.68		2.14		
		Range					
Previous Week	Average Low limit	MIN		Average		MAX	Average High Limit
100 samples	0.5	1.52		2.79		3.29	4.00
March							
404samples	0.5	1.03		2.91		3.65	4.00

NA* - Stone EST Out of Service for maintenance

Bacteriological Sampling		N - Negative	P - Positive
Date	Site	Subdivision	Results
4/26/2021	31	QUAIL MEADOW	N
4/26/2021	32	STONBRIAR	N
4/26/2021	33	WILLOW POND	N
4/26/2021	34	PLANTATION	N
4/26/2021	35	RICHWOODS	N
4/26/2021	36	CYPRESS CREEK	N
4/26/2021	37	FRISCO HEIGHTS	N
4/26/2021	38	PANTHER CREEK	N
4/26/2021	39	PRESTON HIGHLANDS	N
4/26/2021	40	COBB HILL	N
4/27/2021	41	GRIFFIN PARK	N
4/27/2021	42	PEARSON VINEYARD	N
4/27/2021	43	STONE WATER CROSSING	N
4/27/2021	44	FRISCO LAKES	N
4/27/2021	45	QUAIL MEADOW	N
4/28/2021	46	KINGSWOOD	N
4/28/2021	47	STONEBRIAR	N
4/28/2021	48	PRESTON VINEYARDS	N
4/28/2021	49	PRESTON OAKS	N
4/28/2021	50	LIBERTY CROSSING	N
4/28/2021	51	TURNBRIDGE	N
4/28/2021	52	PLANTATION	N
4/28/2021	53	CUSTER CREEK FARMS	N
4/28/2021	54	WILLOW BAY	N
4/28/2021	55	MEADOW HILL ESTATES	N
4/29/2021	56	HEATHER RIDGE	N
4/29/2021	57	GREYHAWK	N
4/29/2021	58	WEST FALLS VILLAGE	N
4/29/2021	59	PARK PLACE	N
4/29/2021	60	WOODSTREAM	N
Month to Date			
Total Samples	120	City Wide	N
Total Samples	0	City Wide	P*
* All repeat samples tested negative; no further action required.			

Disinfection By-products					Units - ug/L	
Total Trihalomethane (TTHM)						
Site	Previous 4 Quarterly Samples					LRAA (80)
1	31.4	31.4	26.2	20.8		27.5
2	31.2	32.8	25.4	21.0		27.6
3	33.8	42.1	25.6	23.5		31.3
4	31.5	39.5	26.4	23.9		30.3
5	31.3	31.5	25.8	25.5		28.5
6	31.5	39.9	25.6	23.8		30.2
7	31.7	38.8	26.3	25.5		30.6
8	31.3	39.7	25.9	21.8		29.7
	Q2 - 20	Q3 - 20	Q4 - 20	Q1 - 21		

Total Haloacetic Acids (HAA)						
Site	Previous 4 Quarterly Samples					LRAA (60)
1	25.0	26.0	17.0	22.0		22.5
2	24.0	24.0	17.0	22.0		21.8
3	25.6	26.0	18.0	19.0		22.2
4	24.2	15.0	15.0	28.0		20.6
5	23.4	24.0	16.0	24.0		21.9
6	21.3	23.0	18.0	20.0		20.6
7	22.0	23.0	13.0	21.0		19.8
8	24.3	27.0	18.0	23.0		23.1
	Q2 - 20	Q3 - 20	Q4 - 20	Q1 - 21		