



Frisco Fire Prevention Office

Minimum Submittal Requirements

This list is provided only to assist in preparation for a submittal and should not be interpreted as the submittal containing all appropriate and needed data. All plans will be reviewed in accordance with the ordinances adopted by the City of Frisco. The following must be submitted with all Fire Permit applications for review:

- Electronic plans are prepared as one PDF, not separate pages.
- Plans are legible.
- Plans are prepared to scale and with a point of compass.
- Plans include all interior and exterior walls.
- All plans must identify the occupancy classification, hazard classification, and type of building construction.
- Plans are signed and dated by the appropriate state licensed design professional
- All product data and material specification sheets are prepared as one PDF, not separate pages.
- A copy of the applicable State Registration Certificate for the responsible agency and/or design professional is provided as a PDF:
 - Automatic Fire Alarm: (ACR-Fire Alarm Planning Superintendent(APS));
 - Automatic Fire Sprinkler: (SCR, SCR-D, SCR-U) – (RME-G, RME-D, RME-U);
 - Extinguisher:(ECR);
 - Texas Registered Professional Engineer

In addition to fire sprinkler submittals the following must be included:

- Hydraulic calculations are prepared as one PDF, not separate pages.
- Fire sprinkler plans are prepared with a site plan including underground water supply, fire hydrants, and Fire Department Connections and access.

In addition to fire alarm submittals the following must be included:

- Battery and voltage drop calculations are prepared as one PDF, not separate pages.
- A Riser diagram and input/output matrix is provided.

Note: Refer to the 2018 edition of the International Fire Code and the 2016 edition of NFPA 13 guidelines for additional required submittal information for working plans.

Failure to follow the guidelines may result in the application not being accepted

Last Revised May 2020

