

Kitchen Hood Suppression System

The Kitchen Hood Suppression System Inspection occurs at the Fire Final. Please reference Fire Final Inspection requirements.

Kitchen Hood Suppression Inspection shall include, but not be limited to, the following:

- Air Test, Utility Shunt, Manual Pull, Exhaust and Make-Up Air.
- Fire Alarm notification.
- K-Class extinguisher placed within 30 feet of cooking appliance.
- Existing system inspections made upon request.